



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	7136-2279:0504
CATEGORY:	7136 - AUDIBLE DEVICES FOR HAZARDOUS LOCATIONS
LISTEE:	European Safety Systems LTD Units 18 & 20, Impress House, Mansell Road, Acton, London W3 7QH, GB Contact: King, Alan +44 (0)20 8746 4326 Email: alan.king@e2s.com
DESIGN:	Model D1x Loudspeakers. Model D1x Loudspeakers followed by L1 or L2, followed by -, followed by V070, R008 or R016 may be used in Class I, Division 1, Groups A, B, C and D Hazardous Locations. Model D1x, followed by L1 or L2, followed by -, followed by V070, R008 or R016. Followed by -D may be used in Class II, Division 1, Groups F and G Hazardous Locations. Refer to listee's printed data sheet for additional detailed product description and operational considerations.
RATING:	Refer to listee's printed datasheet for electrical and environmental ratings.
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, electrical rating, and UL label.
APPROVAL:	Listed as speaker for use in hazardous locations when used with separately listed compatible fire alarm control units. Refer to Manufacturers Installation Instruction Manual for details.
NOTES:	

06-07-18 gt



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 04/24/2024

Listing Expires: 06/30/2025

Authorized By: **David Castillo**, Program Coordinator
Fire Engineering & Investigations Division