
D1xS2

Alarm Horn Sounder with relay / telephone initiation For use in Flammable Gas and Dust Atmospheres







D1xS2F

1. Product Table

Unit Type Code	Nominal	Nominal Nominal nput Voltage Current P2	Nominal Current P3	Voltage Range	Soi Pressui dB	
	input voltage				Max* P2/P3	Nom ^{.†} P2/P3
D1xS2FDC024-T	24Vdc	324mA	740mA	11.5-54Vdc		
D1xS2FAC230-T	115Vac	125mA	282mA	100-240Vac 50/60Hz	120/123 115/	115/118
D1X52FAC230-1	230Vac	78mA	167mA	100-240Vac 50/60H2		
D1xS2HDC024-T	24Vdc	324mA	740mA	11.5-54Vdc		
D1×82HAC220 T	xS2HAC230-T		282mA	100-240Vac 50/60Hz	124/127	119/122
D1X52HAC230-1			167mA	100-240 vac 50/60H2		

*Max = Tone 4 [†]Nom. = Tone 44

The table shows the input current taken by the various sounders.

The current levels shown above are for the 440Hz Continuous tone @ nominal input voltage.

Nominal current at nominal voltage.

*Special 12Vdc version is available – Contact E2S Sales.

Table 1: Electrical Ratings.

Warnings



<u>CAUTION</u>
TO REDUCE THE RISK OF IGNITION OF HAZARDOUS ATMOSPHERES:

DISCONNECT FROM SUPPLY BEFORE OPENING. KEEP TIGHTLY CLOSED WHEN IN OPERATION.

WARNING

FIT SEALING FITTING IN CONDUIT RUNS WITHIN 18 INCHES FROM ENCLOSURE.

EQUIPMENT MUST NOT BE INSTALLED WITH THE HORN FACING UPWARDS OF HORIZONTAL

DO NOT OPEN WHEN AN EXPLOSIVE ATMOSPHERE IS **PRESENT**

DO NOT OPEN WHEN ENERGISED

POTENTIAL ELECTROSTATIC CHARGING HAZARD - CLEAN ONLY WITH A DAMP CLOTH

ENCLOSURE ENTRIES: TWIN M20 X 1.5 / SINGLE 1/2" NPT

IF TEMPERATURE EXCEEDS 70°C AT ENTRY OR 80°C AT BRANCHING POINT USE SUITABLE RATED CABLE AND GLANDS

European Safety Systems Ltd. Impress House, Mansell Road, Acton, London W3 7QH Document No. D190-00-691-IS 15-11-2023 Issue 1

Tel: +44 (0)208 743 8880 Sheet 1 of 7

www.e2s.com

D1xS2

Alarm Horn Sounder with relay / telephone initiation For use in Flammable Gas and Dust Atmospheres



3. Marking & Rating Information

The D1xS2 Alarm Horns comply with the following standards for hazardous locations:

Ctondordo

3.1 ATEX / IECEx & UKEx Ratings

	Standards			
Equipment General EN60079-1:2014/IE0 Equipment Protectio EN60079-31:2014/IE	C60079-0:2017 (ed.7): Explosive Atmospheres - Requirements. C60079-1:2014 (ed.7): Explosive Atmospheres - n by Flameproof Enclosures "d". EC60079-31:2013 (ed.2): Explosive Atmospheres - tion Protection by enclosure "t".			
Model No:	Rating			
D1xS2-DC024-T	Ex db IIC T5 Gb Ta -55°C to +75°C Ex db IIC T6 Gb Ta -55°C to +60°C Ex tb IIIC T95°C Db Ta -55°C to +75°C			
D1xS2-AC230-T	Ex db IIC T5 Gb Ta -55°C to +75°C Ex db IIC T6 Gb Ta -55°C to +60°C Ex tb IIIC T93°C Db Ta -55°C to +75°C			
See Product table t	for electrical ratings of each unit model			

Certificate No.

DEMKO 19ATEX2141X IECEX ULD 19.0008X UKEX UL UL21UKEX2132X

Epsilon x
Equipment Group
and Category:

Ex II 2G

CE Marking and Notified Body No.

2813

UKCA Marking and Notified Body No.



4. Zones, Gas Group, Category and Temperature Classification

The units can be installed in locations with the following conditions:

	Area Classification Gas
	Explosive gas air mixture likely to occur in normal
Zone 1	operation.
Zone 2	Explosive gas air mixture not likely to occur in normal operation, and if it does, it will only exist for a short time.
	Gas Groupings
Group IIA	Propane
Group IIB	Ethylene
Group IIC	Hydrogen and Acetylene
Tem	perature Classification for Gas Applications
T1	450° C
T2	300° C
Т3	200° C
T4	135° C
T5	100°C
T6	85°C (up to 60°C ambient)
	Area Classification Dust
Zone 21	Explosive dust air mixture likely to occur in normal operation.
Zone 22	Explosive dust air mixture not likely to occur in normal operation, and if it does, it will only exist for a short time.
	Dust Groupings
Group IIIA	Combustible Dusts
Group IIIB	Non-Conductive Dusts
Group IIIC	Conductive Dusts
	Equipment Category
2G, 2D	
	Equipment Protection Level
Gb, Gc, Db, D	c
Maximu	ım Surface Temperature for Dust Applications
	95°C (D1xS2-DC024-T) 93°C (D1xS2-AC230-T)
	Ambient Temperature Range
-55°C to +75°C	C (-67°F to +167°F)
	IP Rating
IP66 to EN605 4 / 4X / 3R / 13	29 3 to UL50E / NEMA250
Installation m of the following	ust be carried out in compliance with the latest issue og standards:

EN60079-14 / IEC60079-14: Explosive atmospheres - Electrical installations design, selection and erection

EN60079-10-1 / IEC60079-10-1: Explosive atmospheres

Classification of areas. Explosive gas atmospheres EN60079-10-2 / IEC60079-10-2: Explosive atmospheres Classification of areas. Explosive dust atmospheres

www.e2s.com

European Safety Systems Ltd. Impress House, Mansell Road, Acton, London W3 7QH Document No. D190-00-691-IS Issue 1 15-11-2023

Tel: +44 (0)208 743 8880

D1xS2

Alarm Horn Sounder with relay / telephone initiation For use in Flammable Gas and Dust Atmospheres

warning signals

5. Specific Conditions of Installation

The cable entries have two M20 x 1.5 - 6H entry thread and a single 1/2" NPT thread. If the installation is made using cable glands, only suitably rated ATEx/IECEx or UKEx certified cable glands must be used. They must be suitable for the type of cable being used and also meet the requirements of the current installation standards EN 60079-14 / IEC60079-14.

If the installation is made using conduit, openings must have a sealing fitting connected as close as practical to the wall of the enclosure, but in no case more than the size of the conduit or 50mm, whichever is the lesser.

Any unused cable entries must be closed with suitably rated and UKEx certified blanking plugs.

For high ambient temperatures the cable entry temperature may exceed 70°C or the cable branching point temperature may exceed 80°C and therefore suitable heat resisting cables and cable glands must be used, with a rated service temperature at least as stated below:

Minimum Ratings of Cables & Cable Glands						
Max Ambient Temp (°C)	55	60	65	70	75	
D1xS2-DC024-T Min. Rating (°C)	70	75	80	85	90	
D1xS2-AC230-T Min. Rating (°C)		70	75	80	85	

Table 2: Min. Ratings of Cables & Cable Glands.

The plastic horn is not anti-static and the metallic enclosure has a non-conductive coating. These may generate an ignition-capable level of electrostatic charges under certain extreme conditions. The user should ensure that the equipment is not installed in a location where it may be subjected to external conditions that might cause a build-up of electrostatic charges on non-conducting surfaces.

Only the explosionproof cover is to be used for access to the enclosure for installation, service and maintenance.

Specific Conditions for Safe Use

Flameproof threaded joints and cemented joints are not permitted to be repaired.

Product Mounting and Access 7.

7.1 **Mounting**

The D1x Alarm Horn may be secured to any flat surface using at least two of the three or four 7mm fixing holes. The enclosure provides IP66 protection and is suitable for installation in exterior locations providing it is positioned so that water cannot collect in the horn, and the cable entry is sealed.




Fig 1: Mounting Locations

The Equipment must not be installed with the horn facing upwards of horizontal.



7.2 Installation procedure

- Secure the D1x unit to a flat surface via the three 7mm a.
- fixing holes in the mounting bracket.

 Remove the explosion proof cover of the alarm horn by unscrewing it, taking care not to damage the explosion proof threads in the process (Refer to section 7.4). h.
- Fit an M20/NPT suitably rated cable gland or conduit entry into the hole in the enclosure and connect the field wiring to the appropriate alarm horn terminals as shown in D190-C. to the appropriate alarm horn terminals as shown in D190-06-005 (AC) or D190-06-001. (DC). The power supply terminals are duplicated so that units may be connected in parallel. An end of line monitoring resistor may be fitted to DC units only (see section 10). If the second and third M20/NPT entries are not used, suitably rated stopping plugs must always be fitted. Replace the explosionproof cover of the loudspeaker, taking care not to damage the explosionproof threads. Tighten fully.
- d.

7.3 **Hornless Variants**

The D1x Sounder is also available as a variant with no horn fitted in the factory. The Horn threaded nose portion has a fitment thread of 1-3/8" - 18 UNF (to BS1580 or ANSI B1.1). The customer is responsible for sourcing and correctly fitting a suitable horn that meets all of the relevant safety requirements.

European Safety Systems Ltd. Impress House, Mansell Road, Acton, London W3 7QH Tel: +44 (0)208 743 8880 www.e2s.com Document No. D190-00-691-IS Issue 1 15-11-2023 Sheet 3 of 7

D1xS2

Alarm Horn Sounder with relay / telephone initiation For use in Flammable Gas and Dust Atmospheres



7.4 Access to the Explosionproof Enclosure




Fig 2: Accessing the enclosure

To access the Ex d chamber, loosen the M4 grub screw on the sounder cover. Open the enclosure by turning the sounder cover counter clockwise and remove the cover. Take extreme care not to damage the explosion proof threads in the process.

On completion of the installation the flameproof threaded joint should be inspected to ensure that they are clean and that they have not been damaged during installation.

Ensure the O-ring seal is in place and undamaged.

When fitting the flameproof cover ensure the thread is engaged correctly. Fully tighten the cover all the way, ensure no gap is visible between the cover and base of the sounder enclosure.

8. Installation Requirements

8.1 Safe Installation Requirements



Warning – High voltage may be present, risk of electric shock.

DO NOT open when energised, disconnect power before opening.

The sounder must only be installed by suitably qualified personnel in accordance with the latest issues of the relevant standards.

The product must only be installed by suitably qualified personnel in accordance with the latest issues of the relevant standards.

8.2 Cable Selection and Connections

Electrical connections are to be made into the terminal blocks on the PCBA, using solid wire 0.5-4mm2 / AWG 20-12 or stranded wire, sizes 0.5-2.5mm2 / AWG 24-14. Wire insulation needs to be stripped 8mm. Wires may be fitted securely with crimped ferrules. Terminal screws need to be tightened down with a tightening torque of 0.45 Nm / 3.5 Lb-in.

When selecting the cable size, consideration must be given to the input current that each unit draws (see table 1), the number of sounders on the line and the length of the cable runs. The cable size selected must have the necessary capacity to provide the input current to all the sounders connected to the line.




Fig 3: Wire Preparation.

When connecting wires to the terminals great care should be taken to dress the wires so that when the cover is inserted into the chamber the wires do not exert excess pressure on the terminal blocks. This is

particularly important when using cables with large cross-sectional areas such as 2.5mm².

8.3 Earthing




Fig. 4 Earth Locations

Please note that for AC supply voltage product versions the Earth terminal on the PCBA does not provide an earth connection to the product enclosure. The enclosure must be independently earthed using either the external or internal earth fixing point, (see fig 4 and notes below).

The unit has both a primary internal and secondary external earth fixing point.

Internal earth connections should be made to the internal Earth terminal in the base of the housing using a ring crimp terminal to secure the earth conductor under the earth clamp. The earth conductor should be at least equal in size and rating to the incoming power conductors but at least a minimum of 0.82mm² / 18AWG in size.

External earth connections can be made to the M5 earth stud (see Fig. 4), using a ring crimp terminal to secure the earth conductor to the earth stud. The external earth conductor should be at least 4mm² in size.

The external earth crimp ring should be located between the two M5 plain washers provided and securely locked down with the M5 spring washer and M5 nut.

8.4 Cable Glands, Blanking Elements & Adapters

Ingress Protection

If a high IP (Ingress Protection) rating is required then a suitable sealing washer must be fitted under the cable glands or blanking plugs. A minimum ingress protection rating of IP6X must be maintained for installations in explosive dust atmospheres.

To maintain the ingress protection rating and mode of protection, the cable entries must be fitted with suitably rated cable entry and/or blanking devices during installation.

If entries are fitted with adaptors they must be suitably rated for the application. Fitting of blanking elements into adaptors is not permitted.

Adapters

The D1x sounder range can be supplied with the following types of adapters:

M20 to ½" NPT M20 to ¾" NPT M20 to M25

It is important to note that stopping plugs cannot be fitted onto adapters, only directly onto the M20 entries.

European Safety Systems Ltd. Impress House, Mansell Road, Acton, London W3 7QH www.e2s.com Tel: +44 (0)208 743 8880 Document No. D190-00-691-IS Issue 1 15-11-2023 Sheet 4 of 7

D1xS2

Alarm Horn Sounder with relay / telephone initiation For use in Flammable Gas and Dust Atmospheres

2S warning signals

9. Relay / Telephone Inputs and Settings

9.1 Power Input Terminal for AC & DC Wiring

A suitable power supply (DC or AC voltage) cable should enter via one of the M20 entries and is to be connected to terminal TB1 (see Fig. 5 below). This provides the alarm horn sounder with continuous power.

DC Unit option: Connect the alarm horn sounder power input (+) to the (L/+) terminal (TB1) and power input (-) to the (N/-) at terminal (TB1).

AC Unit option: Connect the alarm horn sounder power input (L) to the (L/+) terminal (TB1) and power input (N) to (N/-) also an earth/ground input to the (E) terminal (TB1). Please note: the earth/ground terminal of TB1 provides termination only for an earth/ground cable. Refer to section 8.3.

For AC and DC voltage wiring diagrams see document D250-06-001




Fig 5: Input Wiring, DIP settings and Header Positions

9.2 Activation, Relay / Telephone Wiring Inputs and Signal Type Header Setting (H1)

The H1 header selection configures the activation signal type.

Select H1 position marked AC for activation from an analogue telephone external ringer output REN1 (typically low current AC voltage around 90 to 150Vac)

Select H1 position marked DC for activation via a DC voltage input of 10 to 60Vdc e.g. a digital PBX external ringer output or a safety system relay output.

The activation input cables should utilise the second M20 cable entry and connect to terminal TB2.

Note: there is no polarity for this input. Factory default H1 is set as AC for activation signal.




Fig 6: Header H1 and H2 Positions

9.3 Unit Activation Mode - Pulsed or Latched, Header Setting (H2)

The H2 header selection configures the alarm horn sounder operation depending upon the type of activation signal.

Select H2 position option marked A for pulsed/cadence mode. The alarm horn sounder audible output will follow the telephone ring cadence or a pulsed relay input.

Option A is the factory default setting.

Select H2 position option marked B for latched mode. The alarm horn sounder audible output will start when an initiation signal is received and will not follow the telephone ringing cadence. See section 9.4

European Safety Systems Ltd. Impress House, Mansell Road, Acton, London W3 7QH www.e2s.com Tel: +44 (0)208 743 8880 Document No. D190-00-691-IS Issue 1 15-11-2023 Sheet 5 of 7

D1xS2

Alarm Horn Sounder with relay / telephone initiation For use in Flammable Gas and Dust Atmospheres



9.4 Unit Latch mode duration DIP switch S1 setting

The relay/telephone latch duration setting is only applicable when Header H2 is set to latched mode via header pin set to position option B.

The alarm horn sounder is activated on the first telephone ring (or relay pulsed input) and any other subsequent inputs and will remain activated for the duration as set by DIP switch S1.

This feature is useful where some countries have short ringing cadence with long off cycle times and the customer requires the alarm sounder to operate for longer periods to better attract attention.

Where this feature becomes essential is for telephone/relay activated beacons to function correctly in these parameters.

Factory default for the relay/telephone latch duration switch setting is 0000.

See table for DIP switch S1 delay timing.

Unit activation period (s) from start of activation signal.	DIP Switch S1 Setting (0000) = All off
1.5	0000
2.0	1000
2.5	0100
3.0	1100
3.5	0010
4.0	1010
4.5	0110
5.0	1110
5.5	1111


10. Settings

Following illustrations show the settings available for D1xS2 Alarm Horn Sounders. See schematic diagram D190-06-001 for details.

10.1 Configuration

See Table 1 for product power supply and Sound Pressure Levels (SPL).

Configuration for DC Units



Configuration for AC Units




Fig 6: AC PCBA.

European Safety Systems Ltd. Impress House, Mansell Road, Acton, London W3 7QH Document No. D190-00-691-IS 15-11-2023 Issue 1

Tel: +44 (0)208 743 8880 Sheet 6 of 7

D1xS2

Alarm Horn Sounder with relay / telephone initiation For use in Flammable Gas and Dust Atmospheres




11. Sounder Tone Selection DIP switch S1 setting


The D1x Alarm Horn Sounders have 64 different tones. The alarm tone is selected by operation of the tone setting DIP switch S1 (see fig 5) on the PCB.

Note DIP switch S2 and multistage selection is not possible with Relay / telephone activation unit.

Default = Switch 2 Not used in this unit.



Default = Switch 1 S1 - Tone 44 110101



(ON = 1, OFF = 0)

Figure 7: DIP switch configuration

The tone table (D221-95-001-IS) shows the switch positions for the 64 tones, dependent on the sounder Stage 1 DIP switch S1 setting.

12. Maintenance, Overhaul and Repair

Maintenance, repair and overhaul of the equipment should only be carried out by suitably qualified personnel in accordance with the current relevant standards:

> EN60079-19/IEC60079-19 Explosive atmospheres - Equipment repair, overhaul and reclamation

> EN 60079-17/IEC60079-17 Explosive atmospheres - Electrical installations inspection and maintenance


Units must not be opened while an explosive atmosphere is present.

If opening the unit during maintenance operations, a clean environment must be maintained and any dust layer removed prior to opening the unit.

Potential electrostatic charging hazard - Clean only with a damp cloth.



Stage 1 Set DIP SW 1 Tone No.	Tone Description	Tone Visual	Stage 1 & 2 DIP SW 1/2 Settings 1 2 3 4 5 6	Stage 3 Set DIP SW 1 (S3)	Stage 4 Set DIP SW 1 (S2 + S3)
1	1000Hz PFEER Toxic Gas	1000Hz ——————————————————————————————————	000000	2	44
2	1200/500Hz @ 1Hz DIN /PFEER P.T.A.P.	500Hz 1s	100000	3	44
3	1000Hz @ 0.5Hz(1s on, 1soff) PFEER Gen. Alarm	1000Hz 1s 1s	010000	2	44
4	1.4KHz-1.6KHz 1s, 1.6KHz-1.4KHz 0.5s NF C 48-265	1600Hz \(0.5s \)	110000	24	1
	544Hz(100mS)/440Hz (400mS) NF S 32-001	1400Hz 1s 544Hz 0.1s	001000		
5	, , ,	440Hz 0.4s 0.4s	001000	19	1
6	1500/500Hz - (0.5s on , 0.5s off) x3 + 1s gap AS4428	500Hz 0.5s 0.5s 0.5s 0.5s 0.5s 1s	101000	44	1
7	500-1500Hz Sweeping 2 sec on 1 sec off AS4428	1500Hz 2s 1s	011000	44	1
8	500/1200Hz @ 0.26Hz (3.3son, 0.5s off) Netherlands -	1200Hz 500Hz 3s 0.5s	111000	24	35
9	NEN 2575 1000Hz (1s on, 1s off)x7 + (7s on, 1s off) IMO Code 1a	1000Hz	000100	34	1
10	1000Hz (1s on, 1s off)x7 + (7s on, 1s off) IMO Code 1a	15	000100	34	1
10			100100		
11	420Hz(0.5s on, 0.5s off)x3 + 1s gap ISO 8201 Temporal Pattern	420Hz 0.5s 0.5s 0.5s 0.5s 1s	010100	1	8
12	1000Hz(0.5s on, 0.5s off)x3 + 1s gap ISO 8201 Temporal Pattern	1000Hz 0.5s 0.5s 0.5s 0.5s 1s	110100	1	8
13	422/775Hz - (0.85 on, 0.5 off) x3 + 1s gap NFPA -	775Hz 10	001100	1	8
14	Temporal Coded 1000/2000Hz @ 1Hz Singapore	422Hz / 0.85 0.5s / 0.85 0.5s / 0.85 0.5s		3	35
	300Hz Continuous (f=300)	1000Hz 0.5s 0.5s	101100		
15 16	300Hz Continuous (f=300) 440Hz Continuous (f=440)		111100	24 24	35 35
17	470Hz Continuous (f=470)		000010	24	35
18	500Hz Continuous IMO code 2 (Low) (f=500)		100010	24	35
19	554Hz Continuous (f=554)		010010	24	35
20	660Hz Continuous (f=660)	f(Hz) ————	110010	24	35 35
21	800Hz IMO code 2 (High) (f=800)		001010	24	35
22	1200Hz Continuous (f=1200) 2000Hz Continuous (f=2000)		011010	24 3	35
24	2000Hz Continuous (f=2000) 2400Hz Continuous (f=2400)		111010	20	35
25	440Hz @0.83Hz (50 (f=440, a=0.6, b=0.6)		000110	44	8
26	cycles/minute) Intermittent (f=470, a=0.55, b=0.55)		100110	44	8
27	470Hz @5Hz - (5 (f-470, 3=0.1, b=0.1)		010110	44	8
	cycles/second) Intermittent (=470, a=0.43, b=0.41) 544Hz @ 1.14Hz - 0.875s Intermittent (f=470, a=0.43, b=0.44)		110110	24	8
28 29	655Hz @ 0.875Hz Intermittent (f=655, a=0.57, b=0.57)		001110	44	8
30	660Hz @0.28Hz - 1.8sec on, 1.8sec off Intermittent (f=660, a=1.8, b=1.8)		101110	24	8
31	660Hz @3.34Hz - 150mS (f=660, a=0.15, b=0.15)	f(Hz) a(s) b(s)	011110	24	8
32	on, 150mS off Intermittent 745Hz @ 1Hz Intermittent (f=745, a=0.5, b=0.5)		111110	24	8
33	800Hz - 0.25sec on, 1 sec off Intermittent (f=800, a=0.25, b=1)		000001	24	8
34	800Hz @ 2Hz IMO code 3.a (High) Intermittent (f=800, a=0.25, b=0.25)		100001	24	8
35	1000Hz @ 1Hz Intermittent (f=1000, a=0.5, b=0.5)		010001	24	8
36	2400Hz @ 1Hz Intermittent (f=2400, a=0.5, b=0.5)		110001	24	8
37	2900Hz @ 5Hz Intermittent (f=2900, a=0.1, b=0.1)		001001	24	8
38	363/518Hz @ 1Hz Alternating (f=363, f1=518, a=0.1)		101001	8	19
39 40	450/500Hz @ 2Hz Alternating (f=450, f1=500, a=0.25) 554/440Hz @ 1Hz Alternating (f=440, f1=554, a=0.5)	f1(Hz)	111001	8 24	19 19
40	554/440Hz @ 0.625Hz Alternating (f=440, f1=554, a=0.5) (f=440, f1=554, a=0.8)	f(Hz) a(s) a(s)	000101	8	19
42	561/760Hz @0.83Hz (50 (f-561_f1-760_3-0.6)		100101	8	19
	cycles/minute) Alternating	f1(Hz)			
43	780/600Hz @ 0.96Hz Alternating (f=600, f1=780, a=0.52)	f(Hz) a(s) a(s)	010101	8	19
44	800/1000Hz @ 2Hz Alternating (f=800, f1=1000, a=0.25)	a(s) a(s)	110101	24	19
45	970/800Hz @ 2Hz Alternating (f=800, f1=970, a=0.25)	f1(Hz) a(s) a(s)	001101	8	19
46	800/1000Hz @ 0.875Hz Alternating (f=800, f1=1000, a=0.57)	f1(Hz)	101101	24	19
47	2400/2900Hz @ 2Hz Alternating (f=2400, f1=2900, a=0.25)	f(Hz) _a(s) a(s)	011101	24	19
48	500/1200Hz @ 0.3Hz Sweeping (f=500, f1=1200, a=3.34)	f1(Hz)	111101	24	12
49	560/1055Hz @ 0.18Hz Sweeping (f=560, f1=1055, a=5.47)	f(Hz) a(s)	000011	24	12
50	560/1055Hz @ 3.3Hz Sweeping (f=560, f1=1055, a=0.3)	<u> </u>	100011	24	12
51	600/1250Hz @ 0.125Hz Sweeping (f=600, f1=1250, a=8)	f1(Hz) f(Hz) a(s)	010011	24	12
52	660/1200Hz @ 1Hz Sweeping (f=660, f1=1200, a=1)		110011	24	12
53	800/1000Hz @ 1Hz Sweeping (f=800, f1=1000, a=1)		001011	24	12
54	800/1000Hz @ 7Hz Sweeping (f=800, f1=1000, a=0.14)		101011	24 24	12
55	800/1000Hz @ 50Hz Sweeping (f=800, f1=1000, a=0.02) 2400/2900Hz @ 7Hz Sweeping (f=2400, f1=2900, a=0.14)	f1(Hz)	011011	24	12
56 57	2400/2900Hz @ 7Hz Sweeping (f=2400, f1=2900, a=0.14) 2400/2900Hz @ 1Hz Sweeping (f=2400, f1=2900, a=1)	f(Hz) a(s)	111011	24	12 12
58	2400/2900Hz @ 50Hz Sweeping (f=2400, f1=2900, a=0.02)		100111	24	12
59	2500/3000Hz @ 2Hz Sweeping (f=2500, f1=3000, a=0.5)		010111	24	12
60	2500/3000Hz @ 7.7Hz Sweeping (f=2500, f1=3000, a=0.13)		110111	24	12
61	800Hz Motor Siren (f=800, a=1.6)	f(Hz)	001111	24	12
62	1200Hz Motor Siren (f=1200, a=2)	a(s)	101111	24	
63	2400Hz Motor Siren (f=2400, a=1.7)	1450Hz 0.255	011111	24	12



EU Declaration of Conformity



Manufacturer: European Safety Systems Ltd.

Impress House, Mansell Road, Acton

London, W3 7QH **United Kingdom**

Authorised Representative: E2S Warnsignaltechnik UG

Charlottenstrasse 45-51

72764 Reutlingen

Germany

Equipment Type: D1xS1, D1xS2

D1xL1, D1xL2

D1xC1X05, D1xC1X10, D1xC2X05, D1xC2X10

D1xB2XH1, D1xB2XH2

Directive 2014/34/EU: Equipment and Protective Systems for use in Potentially Explosive Atmospheres (ATEX) - D1xS1, D1xS2, D1xL1, D1xL2, D1xC1X05, D1xC1X10, D1xC2X05 and D1xC2X10 only

Notified Body for EU type Examination (Module B): UI International Demko A/S

> Borupvang 5A 2750 Ballerup Denmark

EU-type Examination Certificate (Module B): **DEMKO 19 ATEX 2141X**

Notified Body for Quality Assurance Notification / Conformity to EU-type Sira Certification Service based on Notified Body No.: 2813

quality assurance of the production process (Module D):

Unit 6, Hawarden Industrial Park, Hawarden, Deeside, CH5 3US, UK

Quality Assurance Notification (Module D): SIRA 05 ATEX M342

Provisions fulfilled by the equipment: II 2G Ex db IIC T6...T3 GB

II 2D Ex tb IIIC T82°C...145°C Db

Standards applied: EN 60079-0:2018

EN 60079-1:2014 EN60079-31:2014

Regulation EU No. 305/2011: Construction Products Regulation (CPR) - D1xS1FDC024***A1R & D1xS1FDC024***A1G only - tones 1, 2, 5, 8, 40, 44, 53 only

Notified Product Certification Body for Certificate of Constancy of BRE Global Assurance (Ireland) Limited Performance or EC Type Examination Certificate and continuous

Notified Body No.: 2831 surveillance, assessment and evaluation of factory production control: DCU Alpha, Old Finglas Road, Glasnevin, Dublin, D11 KXN4

Certificate of Constancy of Performance or EC Type Examination 2831-CPR-F4858

Certificate:

Standards applied: EN 54-3:2001 + A1:2002 + A2:2006

Directive 2014/90/EU: Marine Equipment Directive (MED) - part codes specified below only - D1xS1FDC024***A1R & D1xS1FDC024***A1G only

Notified Body for EU type Examination (Module B) and Conformity to

EU-type based on quality assurance of the production process (Module

Notified Body No.: 0575 DNV Høvik, Norway

EU-Certificate Type Examination (Module B): MEDB000085K EU Certificate of Conformity for the Quality Assurance System (Module MEDD00000GV

EN 54-3:2014 incl. A1: 2019 Standards applied: IEC 60092-504: 2016 IEC 60533: 2015

DNV AS

EU Declaration of Conformity



<u>Directive 2014/30/EU: Electromagnetic Compatibility Directive (EMC)</u>

Standards applied: EN 61000-6-1:2007 EN 61000-6-2:2005

EN 61000-6-3:2007 / A1:2011 / AC: 2012

EN 61000-6-4:2007 / A1: 2011

Directive 2014/35/EU: Low Voltage Directive (LVD)

Standards applied: EN 60947-1:2007 + A2:2014

Directive 2011/65/EU: Restriction of the use of certain hazardous substances in electrical and electronic equipment (RoHS)

The product and all the components contained within it are in accordance with the restriction of the use of hazardous substances in electrical and electronic equipment, including amendment by Directive 2015/863/EU.

Regulation (EC) 1907/2006: Registration, Evaluation, Authorisation and Restriction of Chemicals (REACH)

The product and all the components contained within it are free from substances of very high concern.

Other Standards and Regulations

EN 60529:1992+A2:2013 - Degrees of protection provided by enclosures (IP code) – enclosure rated IP66/67

On behalf of European Safety Systems Ltd., I declare that, on the date the equipment accompanied by this declaration is placed on the market, the equipment conforms with all technical and regulatory requirements of the above listed directives, regulations and standards.

This Declaration is issued under the sole responsibility of the manufacturer.

Desmond Gayler
Quality Assurance Manager

Document No.: DC-067_Issue_K
Date and Place of Issue: London, 18/03/2024



UKCA Declaration of Conformity



Manufacturer: European Safety Systems Ltd.

Impress House, Mansell Road, Acton

London, W3 7QH **United Kingdom**

Equipment Type: D1xS1, D1xS2

D1xL1, D1xL2

D1xC1X05, D1xC1X10, D1xC2X05, D1xC2X10

Directive UKSI 2016:1107 (as amended by UKSI 2019:696) - Schedule 3A, Part 1: Product or Protective System Intended for use in Potentially Explosive Atmospheres (UKCA)

Notified Body for UK type Examination (Module B): UL International (UK) Ltd

Notified Body No.: 0843

Unit 1-3 Horizon Kingsland Business Park, Wade Road,

Basingstoke, Hampshire RG24 8AH UK

UK-type Examination Certificate (Module B): UL21UKEX2132X

Notified Body for Quality Assurance Notification / Conformity to EU-type

based on quality assurance of the production process (Module D): Sira Certification Service Notified Body No.: 0518

Rake Lane, Eccleston, Chester CH4 9JN, UK

Quality Assurance Notification (Module D): CSAE 22UKQAN0046

Provisions fulfilled by the equipment: II 2G Ex db IIC T6...T3 GB

II 2D Ex tb IIIC T82°C...145°C Db

Standards applied: EN 60079-0:2018

EN 60079-1:2014 EN60079-31:2014

Regulation EU No. 305/2011: Construction Products Regulation (CPR) - D1xS1FDC024***A1R & D1xS1FDC024***A1G only - tones 1, 2, 5, 8, 40, 44, 53 only

Notified Product Certification Body for Certificate of Constancy of **BRE Global Limited** Performance or EC Type Examination Certificate and continuous Notified Body No.: 0832

surveillance, assessment and evaluation of factory production control:

Bucknalls Lane, Garston, Watord, Hertfordshire, UK, WD25 9XX

Certificate of Constancy of Performance or EC Type Examination

Certificate:

0832-UKCA-CPR-F1782

Standards applied: EN 54-3:2001 + A1:2002 + A2:2006

UK Merchant Shipping, Marine Equipment Regulation (MER) 2016 SI 2016/1025- part codes specified below only - D1xS1FDC024***A1R & D1xS1FDC024***A1G

Notified Body for UK type Examination (Module B) and Conformity to

UK-type based on quality assurance of the production process (Module

DNV UK Notified Body No.: 0097

DNV, UK

UK-Certificate Type Examination (Module B): MERB000085K UK Certificate of Conformity for the Quality Assurance System (Module

D):

MFRD00000GV

EN 54-3:2014 incl. A1: 2019 Standards applied:

IEC 60092-504: 2016 IEC 60533: 2015

UKCA Declaration of Conformity



<u>Directive 2014/30/EU: Electromagnetic Compatibility Directive (EMC)</u>

Standards applied: EN 61000-6-1:2007 EN 61000-6-2:2005

EN 61000-6-3:2007 / A1:2011 / AC: 2012

EN 61000-6-4:2007 / A1: 2011

Directive 2014/35/EU: Low Voltage Directive (LVD)

Standards applied: EN 60947-1:2007 + A2:2014

Directive 2011/65/EU: Restriction of the use of certain hazardous substances in electrical and electronic equipment (RoHS)

The product and all the components contained within it are in accordance with the restriction of the use of hazardous substances in electrical and electronic equipment, including amendment by Directive 2015/863/EU.

Regulation (EC) 1907/2006: Registration, Evaluation, Authorisation and Restriction of Chemicals (REACH)

The product and all the components contained within it are free from substances of very high concern.

Other Standards and Regulations

EN 60529:1992+A2:2013 - Degrees of protection provided by enclosures (IP code) - enclosure rated IP66/67

On behalf of European Safety Systems Ltd., I declare that, on the date the equipment accompanied by this declaration is placed on the market, the equipment conforms with all technical and regulatory requirements of the above listed directives, regulations and standards.

This Declaration is issued under the sole responsibility of the manufacturer.

Desmond Gayler Quality Assurance Manager

Document No.: DC-097_Issue_C
Date and Place of Issue: London, 18/03/2024