

Certificate of Compliance

Certificate Number:

UL-US-2400489-1

Report Reference:

E513632-20231211

Issue Date:

2024-01-30

Issued to:

**European Safety Systems Ltd
Impress House
Mansell Rd. London W3 7QH
United Kingdom**

This certificate confirms that representative samples of:

NWFN - Auxiliary Devices for Use in Zone Classified Hazardous Locations

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

**UL 60079-0, Edition 7, Issued 2019-03-26, Revised 2020-04-15,
UL 60079-1, Edition: 7, Issue Date: 2015-9-18, Revision Date:
2020-1-23, UL 60079-11, Edition: 6, Issue Date: 2013-02-15,
Revision Date: 2023-01-25**

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-US-2400489-1
Report reference E513632-20231211
Date 2024-01-30

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Zone 0, AEx ia IIC T4 Ga Intrinsically safe when installed in accordance with Control Drawing No(s). D204-00-501-IS, Manual Signalling Box, Model(s): STExCP8-BG-IR

Zone 0, AEx ia IIC T4 Ga Intrinsically safe when installed in accordance with Control Drawing No(s). D204-00-601-IS, Manual Signalling Box, Model(s): STExCP8-PB-IR, STExCP8-PM-IR, STExCP8-PT-IR

Zone 0, AEx ia IIC T6 Ga Intrinsically safe when installed in accordance with Control Drawing No(s). D204-00-501-IS, Manual Signalling Box, Model(s): STExCP8-BG-I

Zone 0, AEx ia IIC T6 Ga Intrinsically safe when installed in accordance with Control Drawing No(s). D204-00-601-IS, Manual Signalling Box, Model(s): STExCP8-PB-I, STExCP8-PM-I, STExCP8-PT-I

Zone 1, AEx db IIC T5 Gb; Zone 1, AEx db IIC T6 Gb, Manual Signalling Box, Model(s): STExCP8-BG-D-L, STExCP8-PB-D-L, STExCP8-PM-D-L, STExCP8-PT-D-L

Zone 1, AEx db IIC T6 Gb, Manual Signalling Box, Model(s): STExCP8-BG-D, STExCP8-BG-S, STExCP8-BG-S-C, STExCP8-BG-S-L, STExCP8-PB-D, STExCP8-PB-S, STExCP8-PB-S-C, STExCP8-PB-S-L, STExCP8-PM-D, STExCP8-PM-S, STExCP8-PM-S-C, STExCP8-PM-S-L, STExCP8-PT-D, STExCP8-PT-S, STExCP8-PT-S-C, STExCP8-PT-S-L

Zone 1, AEx db IIC T6 Gb; Zone 1, AEx db IIC T5 Gb, Manual Signalling Box, Model(s): STExCP8-BG-D-C, STExCP8-PB-D-C, STExCP8-PM-D-C, STExCP8-PT-D-C

The following equivalency markings may also be marked on the equipment:

For Zone 1, AEx db IIC T5 Gb; Zone 1, AEx db IIC T6 Gb models:
Class I, Division 2, Group A, B, C, D, T6
Class II Division 2, Group F, G, T4
Class III Division 2

For Zone 0, AEx ia IIC T6 Ga Intrinsic Safety Models:
For GNExCP7-XX-I Models: Class I, Division 1, Group A, B, C, D, T6
For GNExCP7-XX-IR Models: Class I, Division 1, Group A, B, C, D, T4

"Class" may be abbreviated to "Cl"
"Division" may be abbreviated to "Div"



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



Certificate of Compliance

Certificate Number:

UL-CA-2400376-1

Report Reference:

E513632-20231211

Issue Date:

2024-01-30

Issued to:

**European Safety Systems Ltd
Impress House
Mansell Rd. London W3 7QH
United Kingdom**

This certificate confirms that representative samples of:

NWFN7 - Auxiliary Devices for Use in Zone Classified Hazardous Locations Certified for Canada

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CSA C22.2 NO. 60079-0:19, 4th Ed., Issue Date: 2019-02-01, CSA C22.2 NO. 60079-1, 3rd Ed., Issue Date: 2016-05-01, CSA C22.2 NO. 60079-11:14, 2nd Ed., Issue Date: 2014-02-01

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-CA-2400376-1
Report reference E513632-20231211
Date 2024-01-30

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Zone 0, Ex ia IIC T4 Ga Intrinsically safe when installed in accordance with Control Drawing No(s). D204-00-501-IS, Manual Signalling Box, Model(s): STExCP8-BG-IR

Zone 0, Ex ia IIC T4 Ga Intrinsically safe when installed in accordance with Control Drawing No(s). D204-00-601-IS, Manual Signalling Box, Model(s): STExCP8-PB-IR, STExCP8-PM-IR, STExCP8-PT-IR

Zone 0, Ex ia IIC T6 Ga Intrinsically safe when installed in accordance with Control Drawing No(s). D204-00-501-IS, Manual Signalling Box, Model(s): STExCP8-BG-I

Zone 0, Ex ia IIC T6 Ga Intrinsically safe when installed in accordance with Control Drawing No(s). D204-00-601-IS, Manual Signalling Box, Model(s): STExCP8-PB-I, STExCP8-PM-I, STExCP8-PT-I

Zone 1, Ex db IIC T5 Gb; Zone 1, Ex db IIC T6 Gb, Manual Signalling Box, Model(s): STExCP8-BG-D-L, STExCP8-PB-D-L, STExCP8-PM-D-L, STExCP8-PT-D-L

Zone 1, Ex db IIC T6 Gb, Manual Signalling Box, Model(s): STExCP8-BG-D, STExCP8-BG-S, STExCP8-BG-S-C, STExCP8-BG-S-L, STExCP8-PB-D, STExCP8-PB-S, STExCP8-PB-S-C, STExCP8-PB-S-L, STExCP8-PM-D, STExCP8-PM-S, STExCP8-PM-S-C, STExCP8-PM-S-L, STExCP8-PT-D, STExCP8-PT-S, STExCP8-PT-S-C, STExCP8-PT-S-L

Zone 1, Ex db IIC T6 Gb; Zone 1, Ex db IIC T5 Gb, Manual Signalling Box, Model(s): STExCP8-BG-D-C, STExCP8-PB-D-C, STExCP8-PM-D-C, STExCP8-PT-D-C

The following equivalency markings may also be marked on the equipment:

For Zone 1, Ex db IIC T6 Gb; Zone 1, Ex db IIC T5 Gb models:
Class I, Division 2, Group A, B, C, D, T6
Class II Division 2, Group F, G, T4
Class III Division 2

For Zone 0, Ex ia IIC T6 Ga Intrinsic Safety Models:
For GNExCP7-XX-I Models: Class I, Division 1, Group A, B, C, D, T6
For GNExCP7-XX-IR Models: Class I, Division 1, Group A, B, C, D, T4

"Class" may be abbreviated to "Cl"
"Division" may be abbreviated to "Div"



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

