

Certificate of Compliance

Certificate Number:

UL-US-2424739-0

Report Reference:

E530713-20240624

Issue Date:

2024-07-01

Issued to:

**European Safety Systems Ltd
Impress House
Mansell Rd. London W3 7QH
United Kingdom**

This certificate confirms that representative samples of:

UIPV - Heat-actuated Devices for Special Application for Use in Hazardous Locations

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 913, Edition 8, Issue Date 2013-12-06, Revision Date 2022-05-10, UL 1203, Edition 6, Issue Date 2023-07-10, UL 121201, 9th Ed., Issue Date: 2017-09-15, Revision Date: 2021-04-01

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-US-2424739-0
Report reference E530713-20240624
Date 2024-07-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
D1xH1-A	Fire Detectors for HazLoc
D1xH1-E	Fire Detectors for HazLoc
D1xH1-H	Fire Detectors for HazLoc
D2xH1-E	Fire Detectors for HazLoc
D2xH1-I	Fire Detectors for HazLoc
D2xH1-IR	Fire Detectors for HazLoc
GNExH1-E	Fire Detectors for HazLoc
GNExH1-H	Fire Detectors for HazLoc
GNExH1-I	Fire Detectors for HazLoc
GNExH1-IR	Fire Detectors for HazLoc
STExH1-A	Fire Detectors for HazLoc
STExH1-E	Fire Detectors for HazLoc
STExH1-H	Fire Detectors for HazLoc



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



Certificate of Compliance

Certificate Number:

UL-CA-2419451-0

Report Reference:

E530713-20240624

Issue Date:

2024-07-01

Issued to:

**European Safety Systems Ltd
Impress House
Mansell Rd. London W3 7QH
United Kingdom**

This certificate confirms that representative samples of:

UIPV7 - Heat-actuated Devices for Special Application for Use in Hazardous Locations Certified for Canada

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CSA C22.2 NO. 25, 4th Ed., Issue Date: 2017-07-01, CSA C22.2 No. 30, Edition 4, Issued 2020-04-01, CSA C22.2 No. 213, Edition 2, Issued 2016-05-01, CSA C22.2 No. 60079-0, Edition 4, Issued 2019-02-01, CSA C22.2 NO. 60079-11:14, 2nd Ed., Issue Date: 2014-02-01, ULC S530, Edition 1, Issued 1991-05-01

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-CA-2419451-0
Report reference E530713-20240624
Date 2024-07-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
D1xH1-A	Fire Detectors for HazLoc
D1xH1-E	Fire Detectors for HazLoc
D1xH1-H	Fire Detectors for HazLoc
D2xH1-E	Fire Detectors for HazLoc
D2xH1-I	Fire Detectors for HazLoc
D2xH1-IR	Fire Detectors for HazLoc
GNExH1-E	Fire Detectors for HazLoc
GNExH1-H	Fire Detectors for HazLoc
GNExH1-I	Fire Detectors for HazLoc
GNExH1-IR	Fire Detectors for HazLoc
STExH1-A	Fire Detectors for HazLoc
STExH1-E	Fire Detectors for HazLoc
STExH1-H	Fire Detectors for HazLoc



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



Certificate of Compliance

Certificate Number:

UL-US-2426150-0

Report Reference:

E530713-20240624

Issue Date:

2024-07-01

Issued to:

**European Safety Systems Ltd
Impress House
Mansell Rd. London W3 7QH
United Kingdom**

This certificate confirms that representative samples of:

UOKH - Heat-automatic Fire Detectors for Use in Zone Classified Hazardous Locations

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

UL 521, Edition 7, Issue Date 1999-02-19, Revision Date 2023-02-28, UL 60079-0, Edition: 7, Issue Date: 2019-3-26, Revision Date: 2020-4-15, UL 60079-1, Edition 7, Issue Date 2015-09-18, Revision Date 2024-04-22, UL 60079-7, 5th Ed., Issue Date: 2017-02-24, Revision Date: 2021-06-03, UL 60079-11, Edition: 6, Issue Date: 2013-02-15, Revision Date: 2023-01-25, UL 60079-31, Edition: 2, Issue Date: 2015-6-12, Revision Date: 2020-8-13

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-US-2426150-0
Report reference E530713-20240624
Date 2024-07-01



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



CERTIFICATE OF COMPLIANCE

Certificate number UL-US-2426150-0
Report reference E530713-20240624
Date 2024-07-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
D1xH1-A	Fire Detectors for HazLoc
D1xH1-E	Fire Detectors for HazLoc
D1xH1-H	Fire Detectors for HazLoc
D2xH1-E	Fire Detectors for HazLoc
D2xH1-I	Fire Detectors for HazLoc
D2xH1-IR	Fire Detectors for HazLoc
GNExH1-E	Fire Detectors for HazLoc
GNExH1-H	Fire Detectors for HazLoc
GNExH1-I	Fire Detectors for HazLoc
GNExH1-IR	Fire Detectors for HazLoc
STExH1-A	Fire Detectors for HazLoc
STExH1-E	Fire Detectors for HazLoc
STExH1-H	Fire Detectors for HazLoc



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



Certificate of Compliance

Certificate Number:

UL-CA-2420528-0

Report Reference:

E530713-20240624

Issue Date:

2024-07-01

Issued to:

**European Safety Systems Ltd
Impress House
Mansell Rd. London W3 7QH
United Kingdom**

This certificate confirms that representative samples of:

**UOKH7 - Heat-automatic Fire Detectors for Use in Zone
Classified Hazardous Locations Certified for Canada**

See Addendum Page for Product Designation(s).

Have been evaluated by UL in accordance with the Standard(s) indicated on this Certificate.

CSA C22.2 No. 60079-0, Edition 4, Issued 2019-02-01, CSA C22.2 NO. 60079-1, 3rd Ed., Issue Date: 2016-05-01, CSA C22.2 No. 60079-7, Edition 2, AMD 1, Issue Date 2016-10, Revision Date 2018-09, CSA C22.2 NO. 60079-11:14, 2nd Ed., Issue Date: 2014-02-01, CSA C22.2 No. 60079-31, Edition: 2, Issue Date: 2015-10, ULC S530, Edition: 1, Issue Date: 1991-05

Additional Information:

See UL Product iQ® at <https://iq.ulprospector.com> for additional information.

This Certificate of Compliance indicates that representative samples of the product described in the certification report have met the requirements for UL certification. It does not provide authorization to apply the UL Mark. Only the Authorization Page that references the Follow-Up Services Procedure for ongoing surveillance provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's Follow-Up Services.

Look for the UL Certification Mark on the product.



David Piecuch
UL Mark Certification Program Manager



Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

CERTIFICATE OF COMPLIANCE

Certificate number UL-CA-2420528-0
Report reference E530713-20240624
Date 2024-07-01



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.



CERTIFICATE OF COMPLIANCE

Certificate number UL-CA-2420528-0
Report reference E530713-20240624
Date 2024-07-01

This is to certify that representative samples of the product as specified on this certificate were tested according to the current UL requirements.

Model	Product Description
D1xH1-A	Fire Detectors for HazLoc
D1xH1-E	Fire Detectors for HazLoc
D1xH1-H	Fire Detectors for HazLoc
D2xH1-E	Fire Detectors for HazLoc
D2xH1-I	Fire Detectors for HazLoc
D2xH1-IR	Fire Detectors for HazLoc
GNExH1-E	Fire Detectors for HazLoc
GNExH1-H	Fire Detectors for HazLoc
GNExH1-I	Fire Detectors for HazLoc
GNExH1-IR	Fire Detectors for HazLoc
STExH1-A	Fire Detectors for HazLoc
STExH1-E	Fire Detectors for HazLoc
STExH1-H	Fire Detectors for HazLoc



David Piecuch
UL Mark Certification Program Manager

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact UL Solutions Customer Service at <https://www.ul.com/contact-us>.

